

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY  
CONDITION CERTIFICATE**

No. 2175Date: 22/05/2026

It is certified that an inspection team headed by Prince J.E (Name of Officers with designation) from Public Health Engineering Department inspected the MODISH PUBLIC SCHOOL, Hodal- Nuh Road, Hodal (Sondhad) Palwal on 13/05/2026 (Date of Inspection) and on the basis of Water Test Report (attached) bearing No. **PWL/01475/5/2026** dated **15/05/2026** of **PALWAL** (PHED Lab) certified that the **MODISH PUBLIC SCHOOL**, Hodal- Nuh Road, Hodal Vill. Sondhad Palwal has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

This Certificate is valid till 22/05/2026 to 21/5/2027.

Signature with Seal: \_\_\_\_\_

Name:- \_\_\_\_\_

Designation: \_\_\_\_\_

**Sub Divisional Engineer  
P.H.E Sub Division  
Hodal**

Name &amp; Address of Office/Department \_\_\_\_\_

To  
MODISH PUBLIC SCHOOL  
Hodal- Nuh Road, Hodal  
Village- Sondhad, Palwal  
(Name & Address of the Institution)



# PUBLIC HEALTH ENGINEERING DEPARTMENT

## DISTRICT WATER TESTING LABORATORY, PALWAL

Website :- <https://pheedharyana.gov.in/>

Memo No:- 869

Date:- 18/05/2026

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification : PWL/01475/5/2026 / Private		Sample Details	Date & Time
Sender :	Modish Public School	Collected By	Rajkumar
Location :	, sondh	Collection Date	13/05/2026 at 11:43
Sample Description :	Drinking Water	Received at lab	13/05/2026 at 14:55
Latitude / Longitude :	77.323789 / 27.917833	Analysis Start Date	15/05/2026
		Analysis End Date	15/05/2026
		Sample Quantity	2000ml

### Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	<1	1 NTU	5 NTU	APHA 24th Edition -2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8) 1984: RA 2023
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5) 1983: 2018
4	Color	<5	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120 B
5	Total Dissolved Solids @ 180°C ± 2°C	418	500 mg/lit.	2000 mg/lit.	APHA 24th Edition -2540 C
6	Total Hardness as CaCo3	110	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2340 C
7	Calcium as Ca	17.63	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	16.03	30 mg/lit.	100 mg/lit.	APHA 24th Edition -3500 -Mg B
9	Total Alkalinity	70	200 mg/lit.	600 mg/lit.	APHA 24th Edition -2320 B
10	Chloride as Cl	89.97	250 mg/lit.	1000 mg/lit.	APHA 24th Edition -4500 Cl-B
11	Sulphate as So4	25	200 mg/lit.	400 mg/lit.	APHA 24th Edition-4500 SO4-E
12	Fluoride as F	0.24	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500-F-D
13	Iron as Fe	<0.10	1.0 mg/lit.	1.0 mg/lit.	APHA 24th Edition-3500-Fe B
14	Nitrate as No3	5.6	45 mg/lit.	45 mg/lit.	APHA 24th Edition-4500-NO3- D
15	pH @ 25°C	7.10	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition -4500-H+ B

#### Remarks :-

- \* The Results Given above are related to the sample as received and tested in PHED PALWAL Lab.
- \* The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- \* The test report can't be used for any publicity or any legal purpose.
- \* Reliability of water sample sample lies with sender/collector of water sample.
- \* To check the sample report online Scan the QR Code below.
- \* The test samples meant for chemical analysis will be disposed off after 7 days from the data of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Water Sample has been found "CONFORMING" to Limits set in BIS10500:2012 for the tested parameters.



Sample analyzed by :

*Vandana*  
VANDANA DESWAL, CHEMIST  
DISTRICT WATER TESTING LABORATORY, PALWAL  
email:-chemist.palwal@pheedharyana.gov.in